

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated.

It is certified that an inspection team headed by Mr. Narender Kumar
(Name of Officers with designation) from N.K. Associates (Licensed Chartered Engineer)
inspected the R.K.L.M. Girls Sr. Sec. School, 2107 D.B. Gupta Road, Karol Bagh, N. Delhi
(Name & Address of the school) on 15-05-2026 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. 10-07-2026
of Delhi Water & General Test Lab, Ranjeet Nagar, N. Delhi - 110008
(Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till One year

Signature with Seal

Name

Designation

Name & Address of the Office / Department P-19 A

NARENDER KUMAR
Chartered Engineer



To R.K.L.M. Girls Sr. Sec. School
2107 D.B. Gupta Road, Karol Bagh, N. Delhi
(Name & Address of the Institution)

Tis Hazari Court,
Delhi-110054.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

J2 B - 11

Commercial Complex, Ranjeet Nagar, New Delhi- 110008
 Phone : 9899554242
 email : dwtl@watersupermart.com • www.delhiwatertestlab.com



Delhi
**WATER & GENERAL
 TEST LAB (P) Ltd.**



AN
 ISO 9001 : 2008
 COMPANY



analysis report

TEST CERTIFICATE

Test certificate No: DWGTL/26-27/067 CB					Issue Date: 10/07/2026	
Party's Name: Principal R.K.L.M. School Karol Bagh, New Delhi-110005					Ref. No.: Nil	
Date of Sample Receipt: 06/07/26					Protocol Used: IS:10500-2012	
Sample Collected by: Party			Types of Water: R.O. Water		Lab code: DWGTL/26-27/067 CB	
					Testing Duration: 06/07/26 TO 09/07/26	
	S.N	Parameters	Units	Test Results	Requirements	Test method Used
Physical analysis	1.	Color	----	< 1	5	IS:3025 Pt-4-2002
	2.	Odor	----	Agreeable	Agreeable	IS:3025 Pt-5-2012
	3.	Taste	----	Agreeable	Agreeable	IS:3025 Pt-8-2006
	4.	Turbidity, NTU	NTU	0.3	1	IS:3025 Pt-10-2006
	5.	pH	----	8.16	6.5-8.5	IS:3025 Pt-11-2002
	6.	Total Dissolved Solid	mg/l	179	500	IS:3025 Pt-16-2003
Chemical analysis	7.	Total Iron as Fe	mg/l	0.08	0.3	IS:3025 Pt-53-2009
	8.	Total Hardness	mg/l	48	200	IS:3025 Pt-21-2009
	9.	Chlorides as Cl	mg/l	39.1	250	IS:3025 Pt-32-2002
	10.	Residual Free chlorine	mg/l	Nil	0.2	IS:3025-Pt.-26-2003
	11.	Sulphate as SO ₄	mg/l	16.3	200	IS:3025pt-24-2009
Microbio-logical test	12.	Fluorides as F-	mg/l	0.21	1.0	IS:3025-Pt.-60-2003
	13.	Coli form	MPN/100ml	Absent	Absent	IS:1622,1981(2003)
	14.	E.Coli	MPN/100ml	Absent	Absent	IS:1622,1981(2003)
REMARKS: With respect to Physical, Chemical & Bacteriological Tests, water confirms to IS: 10500-2012. Therefore, it can be considered fit for drinking purpose.						

G. Singh
 Checked by Sr. Chemist



Authorized signatory

WE UNDERTAKE TESTING OF : WATER * AIR * EFFLUENTS * MATERIALS

The above result are related only to the sample, Endorsement of products is neither inferred nor implied this report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media with out our special written permission. Samples will be destroyed after 15 days from the date of reporting unless otherwise specified.
 Total liability of laboratory is limited to the Invoiced amount

Approved by the Municipal Corporation of Delhi (Health Deptt.)